



EnviroVision
Consultants, Inc.

20-21 Wagaraw Road – Bldg. 35E, Fair Lawn, NJ 07410
PH (973) 636-9145 FAX (973) 636-9144
Email: Envirovision@optonline.net

CLIENT: Mount Laurel School District

Project Number 22-178

PROJECT: Lead in Drinking Water

Harrington Middle School

ADDRESS: 514 Mt. Laurel Rd, Mt. Laurel, NJ 08054

Report Date: May 9, 2022

Field Technician: Cathy DiNardo

As per your request, EnviroVision Consultants, Inc. was contracted by the Mount Laurel School District to conduct Lead (Pb) in drinking water sampling at the Thomas E. Harrington Middle School on April 21, 2022. The sample locations, in addition to unique sample location codes were determined / assigned by school district personnel. The school district performed the proper flushing of the outlets prior to sampling and EnviroVision was instructed to collect only first draw samples for this sampling event. The school district's corresponding flushing logs should be attached to this report.

The facility was closed at the time of sampling in order to prevent occupants from utilizing any water outlets. After flushing, the water in the facility must remain motionless in the plumbing fixtures for a minimum of 8 hours, but no more than 48 hours. Cold water samples were collected in pre-cleaned high-density polyethylene (HDPE) 250mL wide mouth bottles.

The sample was analyzed at EMSL Analytical, Inc. in Cinnaminson, New Jersey (NJDEP#03036), accredited in accordance with NELAC (National Environmental Laboratory Accreditation Conference). The analytical method utilized was inductively coupled plasma mass spectrometry ICP-MS (EPA 200.8).

Results: Forty-four drinking water samples were collected from Harrington Middle School. All of the forty-four samples analyzed were either "None Detected" or less than the US EPA threshold of 15 parts per billion (ppb), or ug/L, for Lead in drinking water. In addition, a required blank was collected for Quality Assurance purposes.

Should you have any questions, or if we could be of any further assistance, please feel free to contact our office. EnviroVision looks forward to providing you with the service and attention to detail you have come to expect from us.

Sincerely,
EnviroVision Consultants, Inc.

Cathy DiNardo

Cathy DiNardo, Project Manager

Attached: Lab results, associated data sheets



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

**Frederick Larson
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410**

5/9/2022

Phone: (973) 636-9145
Fax: (973) 636-9144

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 4/21/2022. The results are tabulated on the attached data pages for the following client designated project:

22-178 Mt. Laurel BOE-Harrington Middle School

The reference number for these samples is EMSL Order #012206495. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Owen McKenna, Chemistry Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012206495
 CustomerID: RAMA51
 CustomerPO:
 ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
 Fax: (973) 636-9144
 Received: 4/21/2022 01:50 PM

Project: 22-178 Mt. Laurel BOE-Harrington Middle School

Analytical Results

Client Sample Description HMSF1
 By B-Wing Lavs
Collected: 4/21/2022
 9:52:00 AM
Lab ID: 012206495-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/6/2022 VD	5/6/2022 09:44 VD

Client Sample Description HMSF2
 By B Girls Locker
Collected: 4/21/2022
 9:56:00 AM
Lab ID: 012206495-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/6/2022 VD	5/6/2022 09:48 VD

Client Sample Description HMSF2-BF
 By B Girls Locker
Collected: 4/21/2022
 9:56:00 AM
Lab ID: 012206495-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/6/2022 VD	5/6/2022 09:50 VD

Client Sample Description HMSF3
 By B Girls Locker
Collected: 4/21/2022
 9:56:00 AM
Lab ID: 012206495-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/6/2022 VD	5/6/2022 09:51 VD

Client Sample Description HMSF3-BF
 By B Girls Locker
Collected: 4/21/2022
 9:56:00 AM
Lab ID: 012206495-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/6/2022 VD	5/6/2022 09:53 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012206495
 CustomerID: RAMA51
 CustomerPO:
 ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
 Fax: (973) 636-9144
 Received: 4/21/2022 01:50 PM

Project: 22-178 Mt. Laurel BOE-Harrington Middle School

Analytical Results

Client Sample Description HMSF4
Boys B Locker
Collected: 4/21/2022 10:02:00 AM
Lab ID: 012206495-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/6/2022 VD	5/6/2022 09:58 VD

Client Sample Description HMSF5
Girls B Locker
Collected: 4/21/2022 10:05:00 AM
Lab ID: 012206495-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.35	1.00 µg/L	5/6/2022 VD	5/6/2022 09:59 VD

Client Sample Description HMSF6
B Wing by office
Collected: 4/21/2022 10:14:00 AM
Lab ID: 012206495-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/6/2022 VD	5/6/2022 10:01 VD

Client Sample Description HMSF7
B Wing by office
Collected: 4/21/2022 10:14:00 AM
Lab ID: 012206495-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/6/2022 VD	5/6/2022 10:02 VD

Client Sample Description HMSF7-BF
B Wing by office
Collected: 4/21/2022 10:14:00 AM
Lab ID: 012206495-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/6/2022 VD	5/6/2022 10:04 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012206495
 CustomerID: RAMA51
 CustomerPO:
 ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
 Fax: (973) 636-9144
 Received: 4/21/2022 01:50 PM

Project: **22-178 Mt. Laurel BOE-Harrington Middle School**

Analytical Results

Client Sample Description HMSF8
 Front A Wing **Collected:** 4/21/2022 10:22:00 AM **Lab ID:** 012206495-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/6/2022 VD	5/6/2022 10:05 VD

Client Sample Description HMSF8-BF
 Front A Wing **Collected:** 4/21/2022 10:22:00 AM **Lab ID:** 012206495-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/6/2022 VD	5/6/2022 10:10 VD

Client Sample Description HMSF9
 By A Wing Lav **Collected:** 4/21/2022 10:26:00 AM **Lab ID:** 012206495-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/6/2022 VD	5/6/2022 10:12 VD

Client Sample Description HMSF10
 By A Wing Lav **Collected:** 4/21/2022 10:26:00 AM **Lab ID:** 012206495-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/6/2022 VD	5/6/2022 10:16 VD

Client Sample Description HMSS1
 A Wing Faculty **Collected:** 4/21/2022 10:32:00 AM **Lab ID:** 012206495-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.28	1.00 µg/L	5/6/2022 VD	5/6/2022 10:18 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012206495
 CustomerID: RAMA51
 CustomerPO:
 ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
 Fax: (973) 636-9144
 Received: 4/21/2022 01:50 PM

Project: 22-178 Mt. Laurel BOE-Harrington Middle School

Analytical Results

Client Sample Description HMSS2
Nurses office
Collected: 4/21/2022
10:38:00 AM
Lab ID: 012206495-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.59	1.00 µg/L	5/6/2022 VD	5/6/2022 10:19 VD

Client Sample Description HMSS3
D Wing Faculty
Collected: 4/21/2022
10:44:00 AM
Lab ID: 012206495-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.50	1.00 µg/L	5/6/2022 VD	5/6/2022 10:21 VD

Client Sample Description HMSF11
D Wing Front
Collected: 4/21/2022
10:45:00 AM
Lab ID: 012206495-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/6/2022 VD	5/6/2022 10:22 VD

Client Sample Description HMSF11-BF
D Wing Front
Collected: 4/21/2022
10:45:00 AM
Lab ID: 012206495-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/6/2022 VD	5/6/2022 10:24 VD

Client Sample Description HMSF12
By D Wing Lavs
Collected: 4/21/2022
10:48:00 AM
Lab ID: 012206495-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/6/2022 VD	5/6/2022 10:26 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012206495
 CustomerID: RAMA51
 CustomerPO:
 ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
 Fax: (973) 636-9144
 Received: 4/21/2022 01:50 PM

Project: 22-178 Mt. Laurel BOE-Harrington Middle School

Analytical Results

Client Sample Description HMSF13
 By D Wing Lavs
Collected: 4/21/2022
 10:48:00 AM
Lab ID: 012206495-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.41	1.00 µg/L	5/5/2022 VD	5/6/2022 08:33 VD

Client Sample Description HMSF14
 E Wing by Aud
Collected: 4/21/2022
 10:55:00 AM
Lab ID: 012206495-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.11	1.00 µg/L	5/5/2022 VD	5/6/2022 08:38 VD

Client Sample Description HMSF15
 E Wing by Aud
Collected: 4/21/2022
 10:55:00 AM
Lab ID: 012206495-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/5/2022 VD	5/6/2022 08:43 VD

Client Sample Description HMSF16
 Aud by Handicap
Collected: 4/21/2022
 10:58:00 AM
Lab ID: 012206495-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/5/2022 VD	5/6/2022 08:44 VD

Client Sample Description HMSF17A
 Aud by Girls
Collected: 4/21/2022
 11:10:00 AM
Lab ID: 012206495-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/5/2022 VD	5/6/2022 08:46 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012206495
 CustomerID: RAMA51
 CustomerPO:
 ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
 Fax: (973) 636-9144
 Received: 4/21/2022 01:50 PM

Project: **22-178 Mt. Laurel BOE-Harrington Middle School**

Analytical Results

Client Sample Description HMSF17A-BF **Collected:** 4/21/2022 **Lab ID:** 012206495-0026
 Aud by Girls 11:10:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/5/2022 VD	5/6/2022 08:47 VD

Client Sample Description HMSF18 **Collected:** 4/21/2022 **Lab ID:** 012206495-0027
 Aud by Girls 11:10:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.39	1.00 µg/L	5/5/2022 VD	5/6/2022 08:49 VD

Client Sample Description HMSF19 **Collected:** 4/21/2022 **Lab ID:** 012206495-0028
 Aud by Boys 11:11:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/5/2022 VD	5/6/2022 08:50 VD

Client Sample Description HMSF20 **Collected:** 4/21/2022 **Lab ID:** 012206495-0029
 Aud by Boys 11:11:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.02	1.00 µg/L	5/5/2022 VD	5/6/2022 08:52 VD

Client Sample Description HMSF21 **Collected:** 4/21/2022 **Lab ID:** 012206495-0030
 E Wing by Faculty 11:18:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/5/2022 VD	5/6/2022 08:53 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012206495
 CustomerID: RAMA51
 CustomerPO:
 ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
 Fax: (973) 636-9144
 Received: 4/21/2022 01:50 PM

Project: 22-178 Mt. Laurel BOE-Harrington Middle School

Analytical Results

Client Sample Description HMSF22
E Wing by Faculty
Collected: 4/21/2022 11:18:00 AM
Lab ID: 012206495-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/5/2022 VD	5/6/2022 08:55 VD

Client Sample Description HMSS4
E Wing Faculty
Collected: 4/21/2022 11:20:00 AM
Lab ID: 012206495-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/5/2022 VD	5/5/2022 22:45 VD

Client Sample Description HMSF23
E Wing by Lav
Collected: 4/21/2022 11:25:00 AM
Lab ID: 012206495-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/5/2022 VD	5/5/2022 22:46 VD

Client Sample Description HMSF24
E Wing by Lav
Collected: 4/21/2022 11:25:00 AM
Lab ID: 012206495-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/5/2022 VD	5/5/2022 22:48 VD

Client Sample Description HMSF25
E Wing by Lav
Collected: 4/21/2022 11:28:00 AM
Lab ID: 012206495-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/5/2022 VD	5/5/2022 22:49 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012206495
 CustomerID: RAMA51
 CustomerPO:
 ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
 Fax: (973) 636-9144
 Received: 4/21/2022 01:50 PM

Project: 22-178 Mt. Laurel BOE-Harrington Middle School

Analytical Results

Client Sample Description HMSF26
 E Wing by Lav
Collected: 4/21/2022 11:28:00 AM
Lab ID: 012206495-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/5/2022 VD	5/5/2022 22:51 VD

Client Sample Description HMSF26-BF
 E Wing by Lav
Collected: 4/21/2022 11:28:00 AM
Lab ID: 012206495-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/5/2022 VD	5/5/2022 22:53 VD

Client Sample Description HMSS5
 C Wing Faculty
Collected: 4/21/2022 11:30:00 AM
Lab ID: 012206495-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/5/2022 VD	5/5/2022 22:54 VD

Client Sample Description HMSF31
 C Wing Faculty
Collected: 4/21/2022 11:31:00 AM
Lab ID: 012206495-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/5/2022 VD	5/5/2022 22:56 VD

Client Sample Description HMSF27
 C Wing By Law
Collected: 4/21/2022 11:43:00 AM
Lab ID: 012206495-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.03	1.00 µg/L	5/5/2022 VD	5/5/2022 22:57 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012206495
 CustomerID: RAMA51
 CustomerPO:
 ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
 Fax: (973) 636-9144
 Received: 4/21/2022 01:50 PM

Project: 22-178 Mt. Laurel BOE-Harrington Middle School

Analytical Results

Client Sample Description HMSF28
 C Wing by Law
Collected: 4/21/2022
 11:43:00 AM
Lab ID: 012206495-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/4/2022 JW	5/4/2022 21:15 JW

Client Sample Description HMSF29
 C Wing Boys Locker
Collected: 4/21/2022
 11:50:00 AM
Lab ID: 012206495-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/4/2022 JW	5/4/2022 21:17 JW

Client Sample Description HMSF30
 C Girls Locker
Collected: 4/21/2022
 11:55:00 AM
Lab ID: 012206495-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/4/2022 JW	5/4/2022 21:19 JW

Client Sample Description HMSB
 Blank
Collected: 4/21/2022
 12:05:00 PM
Lab ID: 012206495-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/4/2022 JW	5/4/2022 21:21 JW

Client Sample Description HMSK6
 Kitchen Coffee
Collected: 4/21/2022
 12:06:00 PM
Lab ID: 012206495-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/4/2022 JW	5/4/2022 21:23 JW

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results



Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

012206495

<p>Customer Information</p> <p>Customer ID: RAMA51</p> <p>Company Name: EnviroVision Consultants Inc.</p> <p>Contact Name: Frederick Larson</p> <p>Street Address: 20-21 Wagaraw Rd. Suite 35E</p> <p>City, State, Zip: Fair Lawn, NJ 07410 Country: Bergen</p> <p>Phone: 973-636-9145</p> <p>Email(s) for Report: info@envirovisionconsultants.com</p>	<p>Billing Information</p> <p>Billing ID: RAMA51</p> <p>Company Name: EnviroVision Consultants Inc.</p> <p>Billing Contact: Frederick Larson</p> <p>Street Address: 20-21 Wagaraw Rd. Suite 35E</p> <p>City, State, Zip: Fair Lawn, NJ 07410 Country: Bergen</p> <p>Phone: 973-636-9145</p> <p>Email(s) for Invoice: info@envirovisionconsultants.com</p>
--	--

Project Information

Project Name/No: **22-178 Mt. Laurel BOE- Harrington Middle School** Purchase Order: _____

EMSL LIMS Project ID: _____ US State where samples collected: **NJ** State of Connecticut (CT) must select project location: Commercial (Taxable) Residential (Non-Taxable)

Sampled By Name: **Cathy DiNardo** Sampled By Signature: _____ No. of Samples in Shipment: _____

Turn-Around-Time (TAT)

3 Hour
 6 Hour
 24 Hour
 32 Hour
 48 Hour
 72 Hour
 96 Hour
 1 Week
 2 Week

Please call ahead for large projects and/or turnaround times 6 Hours or Less. *32 Hour TAT available for select tests only; samples must be submitted by 11:30am.

MATRIX	METHOD	INSTRUMENT	REPORTING LIMIT	SELECTION
CHIPS <input type="checkbox"/> % by wt. <input type="checkbox"/> ppm (mg/kg) <input type="checkbox"/> mg/cm ² *Reporting Limit based on a minimum 0.25g sample weight	SW 846-7000B	Flame Atomic Absorption	0.008% (80ppm)	<input type="checkbox"/>
	SW 846-6010D*	ICP-OES	0.0004% (4ppm)	<input type="checkbox"/>
AIR	NIOSH 7082	Flame Atomic Absorption	4µg/filter	<input type="checkbox"/>
	NIOSH 7300M / NIOSH 7303M	ICP-OES	0.5µg/filter	<input type="checkbox"/>
	NIOSH 7300M / NIOSH 7303M	ICP-MS	0.05µg/filter	<input type="checkbox"/>
WIPE <input type="checkbox"/> ASTM <input type="checkbox"/> NON-ASTM *If no box is checked, non-ASTM Wipe is assumed	SW 846-7000B	Flame Atomic Absorption	10µg/wipe	<input type="checkbox"/>
	SW 846-6010D*	ICP-OES	1.0µg/wipe	<input type="checkbox"/>
TCLP	SW 846-1311 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	SW 846-1311 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
SPLP	SW 846-1312 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	SW 846-1312 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
TTLC	22 CCR App. II, 7000B	Flame Atomic Absorption	40mg/kg (ppm)	<input type="checkbox"/>
	22 CCR App. II, SW 846-6010D*	ICP-OES	2mg/kg (ppm)	<input type="checkbox"/>
STLC	22 CCR App. II, 7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	22 CCR App. II, SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
Soil	SW 846-7000B	Flame Atomic Absorption	40mg/kg (ppm)	<input type="checkbox"/>
	SW 846-6010D*	ICP-OES	2mg/kg (ppm)	<input type="checkbox"/>
Wastewater Unpreserved <input type="checkbox"/> PH<2 Preserved with HNO3 <input type="checkbox"/> PH<2	EPA 200.7	ICP-OES	0.020 mg/L (ppm)	<input type="checkbox"/>
	EPA 200.5	ICP-OES	0.003 mg/L (ppm)	<input type="checkbox"/>
Drinking Water Unpreserved <input checked="" type="checkbox"/> PH<2 Preserved with HNO3 <input type="checkbox"/> PH<2	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	<input checked="" type="checkbox"/>
	40 CFR Part 50	ICP-OES	12 µg/filter	<input type="checkbox"/>
Other:				<input type="checkbox"/>

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
1. HMS F1	By B-wing Lavs	250ML	4/21/22 952
2. HMS F2	By B Girls Locker	250ML	4/21/22 956
3. HMS F2-BF	By B Girls Locker	250ML	4/21/22 956
4. HMS F3	By B Girls Locker	250ML	4/21/22 956
5. HMS F3-BF	By B Girls Locker	250ML	4/21/22 956

Method of Shipment: **Drop Off** Sample Condition Upon Receipt: _____

Relinquished by: **C DiNardo** Date/Time: **4/21/22 140** Received by: **[Signature]** Date/Time: **4/21/22 1:50**

Relinquished by: _____ Date/Time: _____ Received by: **[Signature]** Date/Time: **4/21/22 15:00**

Controlled Document - CQC-25 Lead R16 4/19/2021 *6010C Available Upon Request

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

HNO₃ added 4/22/22 1715 SAM



Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

012206495

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Harrington Middle School

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
6. HMSF4	Boys B Locker	250 mL	4/21/22 1002
7. HMSF5	Girls B Locker	250 mL	4/21/22 1005
8. HMSF6	Bwing By Office	250 mL	4/21/22 1014
9. HMSF7	Bwing By Office	250 mL	4/21/22 1014
10. HMSF7-BF	Bwing By Office	250 mL	4/21/22 1014
11. HMSF8	Front A wing	250 mL	4/21/22 1022
12. HMSF8-BF	Front A wing	250 mL	4/21/22 1022
13. HMSF9	By A wing Lav	250 mL	4/21/22 1026
14. HMSF10	By wing LAV	250 mL	4/21/22 1026
15. HMSS1	A wing Faculty	250 mL	4/21/22 1032
16. HMSS2	Nurses Office	250 mL	4/21/22 1038
17. HMSS3	D wing Faculty	250 mL	4/21/22 1044
18. HMSF11	D wing Front	250 mL	4/21/22 1045
19. HMSF11-BF	D wing Front	250 mL	4/21/22 1045
20. HMSF12	By D wing Lav	250 mL	4/21/22 1048
21. HMSF13	By D wing Lav	250 mL	4/21/22 1048
22. HMSF14	E wing By Aud.	250 mL	4/21/22 1055
23. HMSF15	E wing By Aud	250 mL	4/21/22 1055
24. HMSF16	AUD By Handicap	250 mL	4/21/22 1058
25. HMSF17A	AUD By Girls	250 mL	4/21/22 1110
26. HMSF17A-BF	AUD By Girls	250 mL	4/21/22 1110
27. HMSF18	AUD By Girls	250 mL	4/21/22 1110
28. HMSF19	AUD By Boys	250 mL	4/21/22 1111
29. HMSF20	AUD By Boys	250 mL	4/21/22 1111
30. HMSF21	Ewing By Faculty	250 mL	4/21/22 1118

Method of Shipment: Drop Off		Sample Condition Upon Receipt:	
Relinquished by: C. Miranda	Date/Time: 4/21/22 140	Received by:	Date/Time:
Relinquished by:	Date/Time:	Received by:	Date/Time:

Controlled Document - COC-25 Lead R16 4/19/2021

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

